Daily Checklist for Demolition Contractors

Fill out this checklist as the items are completed. Your Field Liaison may review this document at any time during the day.

Check 'Yes' if the item is completed. Check 'No' if the item was not completed properly.

Yes	No	<u>Equipment</u>
		There are enough hoses to properly wet the house, sidewalk, and to keep dust down.
		Water hoses do not have holes, and are and able to reach all areas of the worksite with proper water pressure.
		Water hoses have nozzles that can spray water in either a single stream, or a wide spray to keep down the dust.
		Proper hydrant wrenches (3 different types) are on site.
		Hydrant compressor to properly shutoff the hydrant.
		Backflow preventer is in use.
		Plugs for hydrants are available.
		All workers on site are wearing DBA Branded Vests.
Yes	No	<u>Preparing for Demolition</u>
		Create a hole in roof with the basket claw, and return the basket claw to the ground.
		Spray a single stream of water into the hole for at least 5 minutes.
		Start time:
		End time:
		Wet the exterior of the house on all sides, including the roof.
Yes	No	<u>During the Demolition</u>
		Water is constantly sprayed on the house. Demolition is completed with the goal of keeping down all clouds of dust.
		The water hose follows the basket claw until the house is fully demolished.

Yes	No	After the Demolition
		Debris was hosed down as it was loaded into the dumpster.
		The sidewalk and street were hosed down after debris was loaded into the dumpster.
		The alley behind the house was hosed down after demolition.
Yes	No	Leaving the site each day
		Contractors must contain the demolition site with orange "snow fence" at the end of each day.
		The orange snow fence should be tightly secured, and not loose. The posts that support the fence must be no wider than 20 feet apart.
		Posts must be 24 inches in the ground, and have 4 feet of post above ground.

Effective Date: Wednesday, October 4, 2017