

**DETROIT HEALTH DEPARTMENT  
ENVIRONMENTAL HEALTH & SAFETY  
FIELD INVESTIGATION REPORT**

RESIDENT/BUSINESS NAME: CODY HIGH SCHOOL

ADDRESS: 18445 CATHEDRAL DETROIT, MI 48227

COMPLAINANT: Follow-up Review

**TYPE OF INVESTIGATION:**

Air Quality _____ Environmental _____	Hazardous Waste _____ Solid Waste _____
--	--

**OTHER:**

**NATURE OF COMPLAINT:** Detroit Public Schools-potential health-related violations observed by BSEED inspectors.

Date of follow-up review: 04/26/2016

**INVESTIGATION SUMMARY:** The Detroit Health Department, Office of Environmental Health and Safety has completed a review of violations for Cody High School.

**Summary:**

All initial violations cited on February 10<sup>th</sup> 2016 for this location have been remediated with **three exceptions.**

1. Repair roof masonry and tuck pointing
2. Seal windows throughout the building as needed.
3. Abate mold around glass block windows as needed.
4. Replace/repaint broken, stained or missing ceiling tiles throughout the third floor.

DHD has been notified that *“more time will be needed to address masonry, tuck pointing and window sealing”, “Abatement around windows with block glass may be needed” “3rd floor ceiling and tiles will be replaced upon repair of the roof, flashings and mortar”.*

An extended deadline of **July 15<sup>th</sup> 2016** has been granted to DPS in regards to the completion of the above remaining repairs/modifications required at Cody High School.

CONDUCTED BY: Detroit Health Department – Environmental Team DATE: 04/26/2016

ROUTINE	Phone COMPLAINT	REFERRAL √
---------	-----------------	---------------