

**DETROIT HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH & SAFETY
FIELD INVESTIGATION REPORT**

RESIDENT/BUSINESS NAME: Nichols Elementary School

ADDRESS: 3020 Burns St, Detroit, MI 48214

COMPLAINANT: Follow-up Review

PHONE: 313-852-0800

TYPE OF INVESTIGATION:

Air Quality	_____	Hazardous Waste	_____
Environmental	_____	Solid Waste	_____

OTHER:

NATURE OF COMPLAINT: Detroit Public Schools-potential health-related violations observed by BSEED inspectors.

Date of follow-up review: 04/26/2016

INVESTIGATION SUMMARY: The Detroit Health Department, Office of Environmental Health and Safety has completed a review of violations for Nichols Elementary School.

FINDINGS/RECOMMENDATIONS:

All initial violations cited on January 25th 2016 for this location have been remediated with **two exceptions.**

1. Replace vacuum and circulating pump upon unit customization.
2. Complete 3rd party air flow inspection

DHD has been notified that a “*vacuum and circulating pump combination ordered and being fabricated.*”, and that DPS is also requesting, “*additional time to schedule 3rd party air quality inspection*”. An extended deadline of **May 30th 2016** has been granted to DPS in regards to the completion of the above remaining repairs/modifications required at Nichols Elementary School.

CONDUCTED BY: City of Detroit Environmental Team

Date: 04/26/16

ROUTINE	Phone COMPLAINT	REFERRAL √
---------	-----------------	---------------