



August 1, 2016

Debra Spring Matrix Head Start 2051 Rosa Parks Boulevard Detroit, Michigan 48216

SUBMITTED VIA EMAIL TO: dspring@matrix.org

SUBJECT: Drinking Water Screening Report

Infinity I

9208 Gratiot Avenue Detroit, Michigan 48213

Dear Ms. Spring:

ATC Group Services, LLC (ATC) is pleased to submit this Drinking Water Screening Report for the subject school. The drinking water samples collected from the school were submitted to TriMatrix Laboratories, for Michigan Department of Environmental Quality (MDEQ) Drinking Water Certified lead analysis.

SCOPE OF WORK

At the request of the Matrix Head Start (Matrix), ATC collected drinking water samples as a general screening for lead at the subject school. Matrix in coordination with the City of Detroit Health Department determined that the screening would consist of collection of water samples from three (3) high priority water outlets (drinking fountains, kitchen/food preparation area faucets, etc.), regularly used by students and staff for drinking, as designated by Matrix personnel. Two (2) samples were collected at each outlet: a first draw (Primary) sample; and a Flush sample. The Primary samples were collected from outlets that had been inactive for a minimum of eight hours. The Flush samples were collected after the water was allowed to run for a minimum of thirty (30) seconds at each of the sample locations.

The drinking water samples were collected in 125 milliliter, wide-mouth sample containers, containing nitric acid (preservative). Each sample container was labeled utilizing a coding system that identified: the type of drinking outlet sampled, Drinking Water Fountain (DWF), Drinking Water Cooler (DWC), Kitchen Faucet (KF) etc.; and a (P) for primary samples and a (F) for flush samples.





The samples were transported under chain of custody to TriMatrix Laboratories, located at 5560 Corporate Exchange Court SE, Grand Rapids Michigan for MDEQ drinking water certified lead analysis, using analytical method EPA 200.8 rev 5.4.

As per the EPA's 3T's for Reducing Lead in Drinking Water in Schools, Revised Technical Guidance (October 2006) analysis of the flush sample(s) was only performed if analysis of the first draw (Primary) sample(s) indicated lead and/or copper concentrations greater than the EPA established Maximum Contaminate Level (MCL).

FINDINGS

Analytical results indicate that none of the samples analyzed were above the EPA recommended limits of 0.015 milligrams per liter (mg/L) for lead. The table below summarizes the analytical results for the samples submitted. The laboratory analytical reports and chain of custody are provided in Attachment A.

Sample Number	Total Lead (Drinking Water)	MCL
1-KS-P-INF I (Kitchen)	<0.0010 mg/L	0.015 mg/L
1-KS-F-INF I (Kitchen)	NA	0.015 mg/L
2-DWC-P-INF I (Hall @ Rear Entrance)	<0.0010 mg/L	0.015 mg/L
2-DWC-F-INF I (Hall @ Rear Entrance)	NA	0.015 mg/L
3-SF-P-INF I (Classroom #1)	<0.0010 mg/L	0.015 mg/L
3-SF-F-INF I (Classroom #1)	NA	0.015 mg/L

Key: NA - Not Analyzed

mg/L- milligrams per liter /parts per million (ppm)



46555 Humboldt Drive Novi, Michigan 48377 Telephone 248-669-5140 www.atcgroupservices.com

LIMITATIONS

The sampling and analysis completed was: a preliminary screening for lead only, to assess lead concentrations (mg/L) at drinking water outlets in the school designated as high use by Matrix, and may not be representative of all drinking water outlets within the school. If lead concentrations are identified above their respective MCL's at any of the drinking water outlets tested, further review of the plumping system, fixtures affected, and testing should be completed to assess the source of the elevated levels of lead, as well as, any other response actions deemed necessary by Matrix.

The drinking water screening proposed and conducted by ATC was devised in cooperation with Matrix, City of Detroit Health Department and utilizing the EPA's 3Ts for Reducing Lead in Drinking Water in Schools and may not meet all of the recommendations provided by the MDEQ "Guidance on Drinking Water Sampling for Lead and Copper at Schools and Daycares on Community Water Supplies" Version 2.0 - April 13, 2016. Future drinking water evaluation and sampling in accordance with the recommendations may be predicated on applicable guidelines by the MDEQ or EPA and will be determined prior to developing a sampling plan for the school.

Sincerely,

ATC Group Services, LLC

Marte & Somble

Martin Gamble

Senior Project Manager

Robert C. Smith

Building Science Department Manager

Robert C. Kiniz

APPENDIX A LABORATORY ANALYTICAL REPORT



June 08, 2016

ATC Group Services Attn: Mr. Robert Smith 46555 Humboldt, Suite 100 Novi, MI 48377

Project: Matrix Head Start

Dear Mr. Robert Smith,

Enclosed is a copy of the laboratory report for the following work order(s) received by TriMatrix Laboratories:

Work Order	Received	Description
1605678	05/27/2016	Infinity I

This report relates only to the sample(s) as received. Test results are in compliance with the requirements of the National Environmental Laboratory Accreditation Program (NELAP) and/or one of the following certification programs:

ANAB DoD-ELAP/ISO17025 (#ADE-1542); Arkansas DEP (#88-0730/13-049-0); Florida DEP (#E87622-24); Georgia EPD (#E87622-24); Illinois DEP (#200026/003329); Kentucky DEP (AL123065/#0021); Michigan DPH (#0034); Minnesota DPH (#491715); New York ELAP (#11776/53116); North Carolina DNRE (#659); Virginia DCLS (#460153/7952); Wisconsin DNR (#999472650); USDA Soil Import Permit (#P330-14-00305).

Any qualification or narration of results, including sample acceptance requirements and test exceptions to the above referenced programs, is presented in the Statement of Data Qualifications and Project Technical Narrative sections of this report. Estimates of analytical uncertainties and certification documents for the test results contained within this report are available upon request.

If you have any questions or require further information, please do not hesitate to contact me.

Sincerely,

Gary L. Wood **Project Chemist**



PROJECT TECHNICAL NARRATIVE(s)

No Project Narrative is associated with this report.

Page 2 of 11



STATEMENT OF DATA QUALIFICATIONS

All analyses have been validated and comply with our Quality Control Program. No Qualification is required.



ANALYTICAL REPORT

Client: ATC Group Services Work Order: 1605678
Project: Matrix Head Start Description: Infinity I

Client Sample ID: **1-KS-P-INF I** Sampled: 05/27/16 06:13

Lab Sample ID: **1605678-01** Sampled By: ATC

Matrix: Drinking Water Received: 05/27/16 16:45

Metals in Drinking Water by EPA 200 Series Methods

Analyte	Analytical Result	RL	Action Limit	Unit	Dilution Factor	Method	Date Time Analyzed	Ву	QC Batch
Lead	<0.0010	0.0010	0.015	mg/L	1	USEPA-200.8 Rev. 5.4	06/07/16 12:28	DSC	1605654



ANALYTICAL REPORT

Client: ATC Group Services Work Order: 1605678
Project: Matrix Head Start Description: Infinity I

Client Sample ID: **2-DWC-P-INF I** Sampled: 05/27/16 06:15

Lab Sample ID: **1605678-03** Sampled By: ATC

Matrix: Drinking Water Received: 05/27/16 16:45

Metals in Drinking Water by EPA 200 Series Methods

Analyte	Analytical Result	RL	Action Limit	Unit	Dilution Factor	Method	Date Time Analyzed	Ву	QC Batch
Lead	<0.0010	0.0010	0.015	mg/L	1	USEPA-200.8 Rev. 5.4	06/07/16 12:30	DSC	1605654



ANALYTICAL REPORT

1605678 Client: **ATC Group Services** Work Order: Infinity I Project: Matrix Head Start Description:

05/27/16 06:17 Client Sample ID: 3-SF-P-INF I Sampled:

Lab Sample ID: 1605678-05 Sampled By: ATC

Matrix: Received: 05/27/16 16:45 **Drinking Water**

Metals in Drinking Water by EPA 200 Series Methods

Analyte	Analytical Result	RL	Action Limit	Unit	Dilution Factor	Method	Date Time Analyzed	Ву	QC Batch
Lead	<0.0010	0.0010	0.015	mg/L	1	USEPA-200.8 Rev. 5.4	06/07/16 12:33	DSC	1605654

Page 6 of 11



QUALITY CONTROL REPORT

Metals in Drinking Water by EPA 200 Series Methods

	Sample	Spike			Spike	Control		RPD	
QC Type	Conc.	Qty.	Result	Unit	% Rec.	Limits	RPD	Limits	RL

Analyte: Lead/USEPA-200.8 Rev. 5.4

QC Batch: 1605654 (Metals Direct Analysis)					Analyzed: 06/07/2016	By: DSC
Method Blank		<0.0010	mg/L			0.0010
Laboratory Control Sample	0.0400	0.0386	mg/L	96	85-115	0.0010



PRETREATMENT SUMMARY PAGE

ATC Group Services Client: **Matrix Head Start** Project:

				Date & Time
Pretreatment	Lab Sample ID	Batch	Ву	Prepared
USEPA 600/R-94/173	1605678-01	1605654	LNS	06/02/16 08:35
	1605678-03	1605654	LNS	06/02/16 08:35
	1605678-05	1605654	LNS	06/02/16 08:35



Chain of Custody Record

COC No. 160539502

The same	52	1/	1/1	5/27 Date	3	3	12	Lay & Recollect &	1240	21/10	2 Blans	- R	
Str.	Distri	SF=Sink Faucet DWC=Drinking Water Cooler KS=Kitchen Sink Faucet Time 3 Relination By	DWC=D KS=K	Date			d B	2. Rylinguished B	Time	8		Tra	Sampler's Signature
mples	lush san	If lead is above detection limits, please analyze flush samples	above detectio	ead is	Ξ			Comments		Carrier	How Shipped? Hand	Но	Sampled By (print) Dawn Winther
												10	
												g.	
												ay	
												7	
Classroom #1				×	2	X DW	o'esa c	618	5/27/16		H-	3-SF-F-INF	90 06
Classroom #1	- Acc				×	X DW	200	617	5/27/16		F -	5 3-SF-P-INF I	<u>ه</u>
Hall @ Rear Entrance				×	2	X DW	200	616	5/27/16		-INF -	4 2-DWC-F-INF I	02 04
Hall @ Rear Entrance					×	X DW	200	615	5/27/16		-INF	3 2-DWC-P-INF	01 03
Kitchen	x			×	2	X DW	3472	614	5/27/16		4F-1	2 1-KS-F-INF I	02 02
Kitchen				200	×	X DW	10200	613	5/27/16		F	1-KS-P-INF	01 01
Total Sample Comments	Tota	Number of Containers Submitted	Number of Co		2	A Matrix	020	Sample	Sample Date	Cooler ID	Field Sample ID	Fig	Schedule Matrix Sample Code Number
and the same	ist)	Container Type (corresponds to Container Packing List)	Type (correspo	ntainer	Co	9			Robert Smith	Rob	robert.smith@atcassociates.net		1602618
F ZnAcNaOHpH>9					Lead -	ments	er (com	CO. 1000-00-0	Contact/Report To		8377 248-669-5140 Fax 248-669-5147	Novi, MI 48377 Phone: 248-6	Jim McFadden Work Order No.
C H ₂ SO ₄ pH<2 D 1+1 HClpH<2				Flush (F	Primary		2	0. / P.O. No. 188BS16284	ect N	Invoice To	46555 Humboldt Drive Suite 100 City, State Zip	46555 Humbo	Project Chemist
A NONE pH~7 B HNO ₃ pH<2				(0)	(P)	ţ.	Infini	ad Start-	Project Name Matrix Head Start- Infinity I	Proje	ervices, LLC	ATC Group Services, LLC	VOA Rack/Tray
PRESERVATIVES					8				1		l	Y	70
1 of 1	Pg.	Analyses Requested	Analyses			3)512 bs.co	d Rapids, MI 49512 www.trimatrixlabs.com	and Rapid	rt SE, Gra 142-7463	5560 Corporate Exchange Court SE, Grand Rapids, MI 49512 Phone (616) 975-4500 Fax (616) 942-7463 www.trimatrixlabs.c	5560 Phone (61)	Cart /)
										CASTAGORINA	THE COLUMN STATE OF THE COLUMN STATE OF THE COLUMN STREET, AND STR		

ORIGINAL - LABORATORY

COPY - SAMPLER

SAMPLE RECEIVING / LOG-IN CHECKLIST

TRIMATRI	X Client QTC GR	New / Add To Project Chemist Sample	1602618			
Recorded by (initials/date) 5/27/	Cooler Qty Re	Thermometer Used Digital Thermome	See Additional Cooler			
Cooler # 7552 / Time 839	Coaler# Time	Cooler# Time	Cooler# Time			
Custody Seals: None	Custody Seals: None Present / Intact Present / Not Intact Coolant Type: Bagged Ice Blue Ice None Coolant Location: Dispersed / Top / Middle / Botte Temp Blank Present: Yes Not Represents	Temp Blank Present: Yes No is: If Present, Temperature Blank Location is:	Custody Seals: None Present / Intact Present / Not Intact Coolant Type: Bagged Ice Blue Ice None Coolant Location: Dispersed / Top / Middle / Bottom Temp Blank Present: Yes No If Present, Temperature Blank Location is Representative Not Representative			
Observed Correction Actual *C.	Observed Correction *C Factor *C Actual	C Observed Correction Actual °C Factor °C Actual °C	Observed Correction Actual *C			
Temp Stank:	Temp Blank:	Temp Blank	Temp Blank			
Sample 1 25.7 0 25.7	Sample 1:	Sample 1:	Sample 1:			
Sample 2 24.6 0 24.6	Sample 2	Sample 2	Sample 2:			
Sample 3 24.4 0 24.4	Sample 3:	Sample 3:	Sample 3:			
3 Sample Average *C: 24.9	3 Sample Average °C:	3 Sample Average °C:	3 Sample Average °C:			
☐ Cooler ID on COC? ☐ VOC Trip Blank received?	Cooler ID on COC? VOC Trip Blank received?	☐ Cooler ID on COC? ☐ Cooler ID on COC? ☐ VOC Trip Blank received? ☐ VOC Trip Blank received?				
If any shaded a	reas checked, complete Sampl	Receiving Non-Conformance and/or	Inventory Form			
Paperwork Received Yes. No Chain of Custody record(s)? Received for Lab Signed/Da Shipping document? Other COC Information TriMatrix COC Other COC ID Numbers:	Extra Contract Contra	☐ ☐ If either is ≥6° C, v ☐ If "Yes", Project ☐ ☐ If "Yes" Comple	nge tag?			
Check COC for Accuracy		Check for Short Hold-Time Prep/Ar				
Yes No Analysis Requested? Sample ID matches COC? Sample Date and Time matches Container type completed on	0002	Bacteriological Air Bags EnCores / Methanol Pre-Preserved Formaldehyde/Aldehyde Green-tagged containers Yellow/White-tagged 1 L ambers (SV P.	AFTER HOURS ONLY: COPIES OF COC TO LAB AREA(S) NONE RECEIVED RECEIVED, COCs TO LAB(S) rep-Lab)			
Sample Condition Summary		Notes				
O O VOC vials / TOX o	olete labels? on on labels?		ank not listed on COC Delivered (Date/Time) ≤1 Hour Gosl Met? Yes: / No			

TRIMATRIX LABORATORIES

SAMPLE PRESERVATION VERIFICATION FORM

page __/ of _/

		page/_ or _/_
Client () TO		Work Order # 1/205/278
Receipt Log# 4-32	Completed By (initials/date)	Project Chemist

OC ID# /62	53950	12	Adjusted by: Date:	DO NOT A	DJUST pH FOR T	HESE CONTA	AINER TYPE
Container Type	5/23	4	13	6	15		
Tag Color	Lt. Blue	Blue	Brown	Red	Red Stripe		
Preservative	NaOH	H ₂ SO ₄	H ₂ SO ₄	HNO ₃	HNO ₃		1153
Expected pH	>12	<2	<2	<2 /	<2		
COC Line #1						7/1	
COC Line #2	127		-7172 E 101		ALC: U	HETT.	
COC Line #3				1/1	Surfail.		
COC Line #4	9-1-19	her		1	H.Salpe-	Total Say	13-11
COC Line #5				1	day.		
COC Line #6	XELL	191 5	Maria Halle	1		776	25
COC Line #7			- No. 414		2. 1		
COC Line #8	Wante.		1000	7 7			FF
COC Line #9			23710				
COC Line #10			CIPTUDE SEA			-2015	

pH	Strip Reagent #	
Ø	6040263	
0		

Aqueous Samples: For each sample and container type, check the box if pH is acceptable. If pH is not acceptable for any sample container, record pH in box, and note on Sample Receiving Checklist and on Sample Receiving Non-Conformance Form. If approved by Project Chemist, add acid or base to the sample to achieve the correct pH. Add up to, but do not exceed 2x the volume initially added at container prep (see table below for initial volumes used). Add orange pH tag to sample container and record information requested. Record adjusted pH on this form. Do not adjust pH for container types 6 and 15.

OC ID#			Adjusted by: Date:	DO NOT A	DJUST pH FOR	THESE CONT	AINER TYPE
Container Type	5/23	4	13	6	15		
Tag Color	Lt. Blue	Blue	Brown	Red	Red Stripe	11.0	
Preservative	NaOH	H ₂ SO ₄	H ₂ SO ₄	HNO ₃	HNO ₃		0.62
Expected pH	>12	<2	<2	<2	<2		
COC Line #1		P. 1	18.5	A TIENTE			E 9 T
COC Line #2					-		
COC Line #3	MASP -	TIFIE		Park Burn		We Ja	100
COC Line #4	-					T. P.	CONTRACT OF
COC Line #5	SINE A		W. III	-19		Alta S	10.37
COC Line #6	9///		The way				1
COC Line #7	71,276	1	D. 44 3 34	P. BANK		4571	100
COC Line #8			10 - 5 -	76 1	The state of		1
COC Line #9		160	- J.E.	S.F. KEGATI		- Harris	- 3
COC Line #10		THE STATE OF THE S			100		

Container Size (mL)	Original Vol. of Preservative (mL)				
Container Type 5	NaOH				
500	2.5				
1000	5.0				
Container Type 4	H ₂ SO ₄				
125	0.5				
250	1.0 2.0 4.0				
500					
1000					
Container Type 13	H ₂ SO ₄				
500	2.5				