



GS GROUP LLC
Green S.P.A.C.E.S Protect Our Earth

Allen Academy Water Sampling Lead Analysis Report

1. INTRODUCTION

1.1. GENERAL

This report presents the results of our water sampling performed at the site of Allen Academy, 8666 Quincy, Detroit, MI., on May 10th, 2016. The sample results taken in conjunction with this investigation are also presented on Appendix 1.

1.2. OBJECTIVES AND SCOPE

In general, the objectives of this investigation were to:

Accurately evaluate water outlets for lead above the EPA Maximum Contaminate Level (MCL).

1.3. AUTHORIZATION

Authorization was provided by phone for our Professional Services by Tony Hitchcock on April 26th, 2016.

2. SITE INVESTIGATIONS

2.1. FIELD PROGRAM

In order to sample and evaluate water, GSES took six samples, a First Draw sample and a Flush sample, from three different locations on the site.

The field portion of our investigation was under control and continual supervision of an experienced member of our field scientist staff.

2.2 LABORATORY TESTING

2.2.1. General

In accordance with ASTM D3559 and the U.S. Environmental Protection Agency guidelines for lead in drinking water at schools and child care facilities, we took two samples: first draw and flush, which is the required testing standard for drinking water lead contamination.

Results of the tests indicate that the water is below the threshold for lead



GS GROUP LLC
Green S.P.A.C.E.S Protect Our Earth

contamination. A copy of the lab report and Chain of Custody is attached (Appendix 1).

3. DISCUSSIONS AND RECOMMENDATIONS

3.1. DISCUSSIONS OF FINDINGS

The water results are below the threshold for lead contamination.

We appreciate the opportunity of providing this service for you. If you have any questions concerning this report or require additional information, please do not hesitate to contact the undersigned.

Respectfully submitted,

Michael Etters
Field Scientist

Monica Starks, CIEC
Principal

Council-certified Indoor Environmental
Consultant Board-awarded by the
American Council for Accredited
Certification



Appendix 1, Lab Results, Chain of Custody



GS GROUP LLC
Green S.P.A.C.E.S Protect Our Earth

APPENDIX 1
Laboratory Results and Chain of Custody

17800 Woodward Ave Suite 200
Detroit, MI 48203

Laboratory ID: 0055

National Testing Laboratories, Ltd
556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 354717
5/20/2016

8666 Quincy - 48204

Customer: G. S. Group
Monica Starks
17800 Woodward Ave
#200
Detroit, MI 48203

Source: Allen Academy, S-01-KC-01-P
Source City: Detroit
Source State: MI

Date/Time Received: 5/10/2016 13:30
Collected by: M. Etters

The results herein conform to TNI and ISO/IEC 17025:2005 standards, where applicable, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

- "ND" This contaminant was not detected at or above our lower reporting limit (LRL)
- "NA" Not Analyzed
- "Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.
- "LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.
- "DF" This column indicates the contaminant dilution factor.

Report Notes:

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prapped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.015	mg/L	0.001	0.005	1	5/10/2016 06:18		5/18/2016

These test results may be used for compliance purpose as required.

Analyst	Tests
EC	200.8



James Abston, Operations Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

Laboratory ID: 0055

National Testing Laboratories, Ltd
556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 354718

5/20/2016

Customer: G. S. Group
Monica Starks
17800 Woodward Ave
#200
Detroit, MI 48203

Source: Allen Academy, S-01-KC-01-F
Source City: Detroit
Source State: MI

Date/Time Received: 5/10/2016 13:30

Collected by: M. Etters

The results herein conform to TNI and ISO/IEC 17025:2005 standards, where applicable, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any "Level Detected" marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.015	mg/L	0.001	ND	1	5/10/2016 06:18		5/18/2016

These test results may be used for compliance purpose as required.

Analyst	Tests
EC	200.8



James Abston, Operations Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

Laboratory ID: 0055

National Testing Laboratories, Ltd
556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 354719

5/20/2016

Customer: G. S. Group
Monica Starks
17800 Woodward Ave
#200
Detroit, MI 48203

Source: Allen Academy, S-01-WC-02-P
Source City: Detroit
Source State: MI

Date/Time Received: 5/10/2016 13:30

Collected by: M. Eppers

The results herein conform to TNI and ISO/IEC 17025:2005 standards, where applicable, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.


"DF" This column indicates the contaminant dilution factor.

Report Notes:

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.015	mg/L	0.001	ND	1	5/10/2016 06:18		5/18/2016

These test results may be used for compliance purpose as required.

Analyst	Tests
EC	200.8



James Abston, Operations Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

Laboratory ID: 0055

National Testing Laboratories, Ltd
556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 354720

5/20/2016

Customer: G. S. Group
Monica Starks
17800 Woodward Ave
#200
Detroit, MI 48203

Source: Allen Academy, S-01-WC-02-F
Source City: Detroit
Source State: MI

Date/Time Received: 5/10/2016 13:30

Collected by: M. Elters

The results herein conform to TNI and ISO/IEC 17025:2005 standards, where applicable, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.015	mg/L	0.001	ND	1	5/10/2016 06:18		5/18/2016

These test results may be used for compliance purpose as required.

Analyst	Tests
EC	200.8



James Abston, Operations Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

Laboratory ID: 0055

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 354721

5/20/2016

Customer: G. S. Group
Monica Starks
17800 Woodward Ave
#200
Detroit, MI 48203

Source: Allen Academy, S-01-BBF-03-P
Source City: Detroit
Source State: MI

Date/Time Received: 5/10/2016 13:30

Collected by: M. Etters

The results herein conform to TNI and ISO/IEC 17025:2005 standards, where applicable, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.015	mg/L	0.001	0.001	1	5/10/2016 06:18		5/18/2016

These test results may be used for compliance purpose as required.

Analyst	Tests
EC	200.8



James Abston, Operations Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

Laboratory ID: 0055

National Testing Laboratories, Ltd
556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 354722

5/20/2016

Customer: G. S. Group
Monica Starks
17800 Woodward Ave
#200
Detroit, MI 48203

Source: Allen Academy, S-01-BBF-03-F
Source City: Detroit
Source State: MI

Date/Time Received: 5/10/2016 13:30

Collected by: M. Eiters

The results herein conform to TNI and ISO/IEC 17025:2005 standards, where applicable, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.015	mg/L	0.001	ND	1	5/10/2016 06:18		5/18/2016


These test results may be used for compliance purpose as required.

Analyst	Tests
EC	200.8



James Abston, Operations Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.



1-800-458-3330

General Compliance

Order Number: 2076912
 Order Date: 04/19/2016
 Sample Number:
 Product: Lead Only
 Sample Paid: No Payment Method:
 TSR: EF

354717

Sold To:
 G. S. Group
 Monica Starks
 17800 Woodward Ave
 Detroit MI 48203

Date Sampled: 5/10/16
 Time Sampled: 6:18 Please Use Military Time, e.g. 3:00pm = 15:00
 Check Time Zone: EST CST MST PST
 Client Name: Allen Academy
 Phone Number: 248-469-4449 xt 700
 Fax Number: _____

PWS ID# (if applicable): N/A

Sample ID or Source: S-01-KC-01-P

Source Type: Spring Well Municipal Surface
 Other: _____

City & State: Detroit, Mi.
(If Different than Above)

Sample Collected By: [Signature]
(Signature)

Sample Collected By: Michael Eppers
(Please Print)

Form Completed By: Michael Eppers

Additional Comments: 3 locations sampled at this school. This is location #1
First draw.

For Laboratory Use ONLY
Lab Accounting Information: Payment \$: _____ Check #: _____
Lab Comments/Special Instructions: State Forms: _____
Lab Sample Information: Date Received: <u>5/10/16</u> Time Received: <u>13:30</u> Received By: <u>AF</u> <input checked="" type="checkbox"/> Sample receipt criteria checked & acceptable. <input type="checkbox"/> Deviations from acceptable sample receipt criteria noted on PSA form.

INCOMPLETE INFORMATION MAY DELAY ANALYSIS AND/OR INVALIDATE RESULTS



1-800-458-3330

General Compliance

Order Number: 2076912
Order Date: 04/19/2016
Sample Number:
Product: Lead Only
Sample Paid: No Payment Method:
TSR: EF

354718



Sold To:
G. S. Group
Monica Starks
17800 Woodward Ave
Detroit MI 48203

Date Sampled: 5/10/16
Time Sampled: 6:18 Please Use Military Time, e.g. 3:00pm = 15:00
Check Time Zone: EST CST MST PST
Client Name: Allen Academy
Phone Number: 248-469-4449 xt 700
Fax Number: _____

PWS ID# (if applicable): N/A

Sample ID or Source: 3-01-KC-01-F

Source Type: Spring Well Municipal Surface
 Other: _____

City & State: Detroit, Mi.
(If Different than Above)

Sample Collected By: [Signature]
(Signature)

Sample Collected By: Michael Eppers
(Please Print)

Form Completed By: Michael Eppers

Additional Comments: 3 locations sampled at this school. This is location # 1
Flush Sample.

For Laboratory Use ONLY	
Lab Accounting Information:	
Payment \$:	_____
Check #:	_____
Lab Comments/Special Instructions:	
State Forms:	
Lab Sample Information:	
Date Received:	<u>5/10/16</u>
Time Received:	<u>18:30</u>
Received By:	<u>DF</u>
<input checked="" type="checkbox"/> Sample receipt criteria checked & acceptable. <input type="checkbox"/> Deviations from acceptable sample receipt criteria noted on PSA form.	

INCOMPLETE INFORMATION MAY DELAY ANALYSIS AND/OR INVALIDATE RESULTS



1-800-458-3330

General Compliance

Order Number: 2076912 354719
Order Date: 04/19/2016
Sample Number:
Product: Lead Only
Sample Paid: No Payment Method:
TSR: EF



Sold To:
G. S. Group
Monica Starks
17800 Woodward Ave
Detroit MI 48203

For Laboratory Use ONLY
Lab Accounting Information: Payment \$: _____ Check #: _____
Lab Comments/Special Instructions: State Forms:
Lab Sample Information: Date Received: <u>5/10/16</u> Time Received: <u>13:30</u> Received By: <u>BF</u> <input checked="" type="checkbox"/> Sample receipt criteria checked & acceptable. <input type="checkbox"/> Deviations from acceptable sample receipt criteria noted on PSA form.

Date Sampled: 5/10/16
Time Sampled: 6:18 Please Use Military Time, e.g. 3:00pm = 15:00
Check Time Zone: EST CST MST PST
Client Name: Allen Academy
Phone Number: 248-469-4449 xt 700
Fax Number: _____

PWS ID# (if applicable): N/A

Sample ID or Source: S-01-WC-02-P
Source Type: Spring Well Municipal Surface
 Other:

City & State: Detroit, Mi.
(If Different than Above)

Sample Collected By: [Signature]
(Signature)

Sample Collected By: Michael Eppers
(Please Print)

Form Completed By: Michael Eppers

Additional Comments: 3 locations sampled at this school. This is location #2
First draw.

INCOMPLETE INFORMATION MAY DELAY ANALYSIS AND/OR INVALIDATE RESULTS



1-800-458-3330

General Compliance

Order Number: 2076912

Order Date: 04/19/2016

354720

Sample Number:



Product: Lead Only

Sample Paid: No Payment Method:

TSR: EF

Sold To:
G. S. Group
Monica Starks
17800 Woodward Ave
Detroit

MI 48203

Date Sampled: 5/10/16

Time Sampled: 6:18 Please Use Military Time, e.g. 3:00pm = 1500

Check Time Zone: EST CST MST PST

Client Name: Allen Academy

Phone Number: 248-469-4449 xt 700

Fax Number: _____

PWS ID# (if applicable): N/A

Sample ID or Source: S-01-WC-02-F

Source Type: Spring Well Municipal Surface
 Other:

City & State: Detroit, Mi.
(If Different than Above)

Sample Collected By: [Signature]
(Signature)

Sample Collected By: Michael Efters
(Please Print)

Form Completed By: Michael Efters

Additional Comments:

3 locations sampled at this school. This is location #2
Flush Sample.

For Laboratory Use ONLY	
Lab Accounting Information:	
Payment \$:	_____
Check #:	_____
Lab Comments/Special Instructions:	
State Forms:	
Lab Sample Information:	
Date Received:	<u>5/10/16</u>
Time Received:	<u>13:30</u>
Received By:	<u>EF</u>
<input checked="" type="checkbox"/> Sample receipt criteria checked & acceptable. <input type="checkbox"/> Deviations from acceptable sample receipt criteria noted on PSA form.	

INCOMPLETE INFORMATION MAY DELAY ANALYSIS AND/OR INVALIDATE RESULTS



1-800-458-3330

General Compliance

Order Number: 2076912
Order Date: 04/19/2016
Sample Number:

354721



Product: Lead Only
Sample Paid: No Payment Method:
TSR: EF

Sold To:
G. S. Group
Monica Starks
17800 Woodward Ave
Detroit MI 48203

Date Sampled: 5/10/16
Time Sampled: 6:18 Please Use Military Time, e.g. 3:00pm = 15:00
Check Time Zone: EST CST MST PST
Client Name: Allen Academy
Phone Number: 248-469-4449 xt 700
Fax Number:

PWS ID# (if applicable): N/A

Sample ID or Source: S-01-BBF-03-P
Source Type: Spring Well Municipal Surface
 Other:

City & State: Detroit, Mi.
(If Different than Above)

Sample Collected By: *[Signature]*
(Signature)

Sample Collected By: Michael Eppers
(Please Print)

Form Completed By: Michael Eppers

Additional Comments:
3 locations sampled at this school. This is location #3
First draw

For Laboratory Use ONLY	
Lab Accounting Information:	
Payment \$:	_____
Check #:	_____
Lab Comments/Special Instructions:	
State Forms:	
Lab Sample Information:	
Date Received:	5/10/16
Time Received:	13:30
Received By:	ME
<input checked="" type="checkbox"/> Sample receipt criteria checked & acceptable. <input type="checkbox"/> Deviations from acceptable sample receipt criteria noted on PSA form.	

INCOMPLETE INFORMATION MAY DELAY ANALYSIS AND/OR INVALIDATE RESULTS



1-800-458-3330

General Compliance

Order Number: 2076912 354772
 Order Date: 04/19/2016
 Sample Number: 
 Product: Lead Only
 Sample Paid: No Payment Method:
 TSR: EF


Sold To:
 G. S. Group
 Monica Starks
 17800 Woodward Ave
 Detroit MI 48203

Date Sampled: 5/10/16
 Time Sampled: 6:15 Please Use Military Time, e.g. 3:00pm = 15:00
 Check Time Zone: EST CST MST PST
 Client Name: Allen Academy
 Phone Number: 248-469-4449 xt 700
 Fax Number: _____

PWS ID# (if applicable): N/A

Sample ID or Source: S-01-BBF-03-F
 Source Type: Spring Well Municipal Surface
 Other: _____

City & State: Detroit, Mi.
(If Different than Above)

Sample Collected By: 
(Signature)

Sample Collected By: Michael Eppers
(Please Print)

Form Completed By: Michael Eppers

Additional Comments: 3 locations sampled at this school. This is location # 3
Flush Sample

For Laboratory Use ONLY
Lab Accounting Information: Payment \$: _____ Check #: _____
Lab Comments/Special Instructions: State Forms: _____
Lab Sample Information: Date Received: <u>5/10/16</u> Time Received: <u>13:30</u> Received By: <u>EF</u> <input checked="" type="checkbox"/> Sample receipt criteria checked & acceptable. <input type="checkbox"/> Deviations from acceptable sample receipt criteria noted on PSA form.

INCOMPLETE INFORMATION MAY DELAY ANALYSIS AND/OR INVALIDATE RESULTS