



GS GROUP LLC
Green S.P.A.C.E.S Protect Our Earth

Caesar Chavez Academy Water Sampling Lead Analysis Report

1. INTRODUCTION

1.1. GENERAL

This report presents the results of our water sampling performed at the site of Caesar Chavez Academy, 4100 Martin Rd., Detroit MI., on July 29th, 2016. The sample results taken in conjunction with this investigation are also presented on Appendix 1.

1.2. OBJECTIVES AND SCOPE

In general, the objectives of this investigation were to:

Accurately evaluate water outlets for lead above the EPA Maximum Contaminate Level (MCL).

1.3. AUTHORIZATION

Authorization was provided by phone for our Professional Services by John Diegel on July 21st, 2016.

2. SITE INVESTIGATIONS

2.1. FIELD PROGRAM

In order to sample and evaluate water, GSES took six samples, a First Draw sample and a Flush sample, from three different locations on the site.

The field portion of our investigation was under control and continual supervision of an experienced member of our field scientist staff.

2.2 LABORATORY TESTING

2.2.1. General

In accordance with ASTM D3559 and the U.S. Environmental Protection Agency guidelines for lead in drinking water at schools and child care facilities, we took two samples: first draw and flush, which is the required testing standard for drinking water lead contamination.



GS GROUP LLC

Green S.P.A.C.E.S Protect Our Earth

Results of the tests indicate that the water is below the threshold for lead contamination. A copy of the lab report and Chain of Custody is attached (Appendix 1).

3. DISCUSSIONS AND RECOMMENDATIONS

3.1. DISCUSSIONS OF FINDINGS

The water results are below the threshold for lead contamination.

We appreciate the opportunity of providing this service for you. If you have any questions concerning this report or require additional information, please do not hesitate to contact the undersigned.

Respectfully submitted,

Michael Etters
Field Scientist

Monica Starks, CIEC
Principal

Council-certified Indoor Environmental
Consultant Board-awarded by the
American Council for Accredited
Certification



Appendix 1, Lab Results, Chain of Custody

17800 Woodward Ave Suite 200
Detroit, MI 48203



GS GROUP LLC
Green S.P.A.C.E.S Protect Our Earth

APPENDIX 1
Laboratory Results and Chain of Custody

17800 Woodward Ave Suite 200
Detroit, MI 48203

ANALYTICAL REPORTS

SAMPLE CODE: 358692
8/10/2016

Customer: G. S. Group
 Monica Starks
 17800 Woodward Ave #200
 Detroit, MI 48203

Source: Caesar Chavez, S-02-GF-01-P
Source City: Detroit
Source State: MI

Date/Time Received: 8/3/2016 14:00
Collected by: A. Hayden

The results herein conform to TNI and ISO/IEC 17025:2005 standards, where applicable, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

- Legend:**
- Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.
 - "ND" This contaminant was not detected at or above our lower reporting limit (LRL)
 - "NA" Not Analyzed
 - "Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.
 - "LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.
 - "DF" This column indicates the contaminant dilution factor.

Report Notes:

| Fed Id # | Contaminant | Method | Standard | Units | LRL | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|------------------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| Inorganic Analytes - Metals | | | | | | | | | | |
| 1030 | Lead | 200.8 | 0.015 | mg/L | 0.001 | 0.001 | 1 | 7/29/2016 08:30 | | 8/8/2016 |

These test results may be used for compliance purpose as required.

| Analyst | Tests |
|---------|-------|
| JP | 200.8 |



James Abston, Operations Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 358693

8/10/2016

Customer: G. S. Group
 Monica Starks
 17800 Woodward Ave #200
 Detroit, MI 48203

Source: Caesar Chavez, S-02-GF-01-F
Source City: Detroit
Source State: MI

Date/Time Received: 8/3/2016 14:00

Collected by: A. Hayden

The results herein conform to TNI and ISO/IEC 17025:2005 standards, where applicable, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

| Fed Id # | Contaminant | Method | Standard | Units | LRL | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|------------------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| Inorganic Analytes - Metals | | | | | | | | | | |
| 1030 | Lead | 200.8 | 0.015 | mg/L | 0.001 | ND | 1 | 7/29/2016 08:30 | | 8/8/2016 |

These test results may be used for compliance purpose as required.

| Analyst | Tests |
|---------|-------|
| JP | 200.8 |



James Abston, Operations Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

ANALYTICAL REPORTS

SAMPLE CODE: 358688
8/10/2016

Customer: G. S. Group
 Monica Starks
 17800 Woodward Ave #200
 Detroit, MI 48203

Source: Caesar Chavez, S-02-BF-02-P
Source City: Detroit
Source State: MI

Date/Time Received: 8/3/2016 14:00
Collected by: A. Hayden

The results herein conform to TNI and ISO/IEC 17025:2005 standards, where applicable, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:
 Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

- "ND" This contaminant was not detected at or above our lower reporting limit (LRL)
- "NA" Not Analyzed
- "Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.
- "LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.
- "DF" This column indicates the contaminant dilution factor.

Report Notes:

| Fed Id # | Contaminant | Method | Standard | Units | LRL | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|------------------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| Inorganic Analytes - Metals | | | | | | | | | | |
| 1030 | Lead | 200.8 | 0.015 | mg/L | 0.001 | ND | 1 | 7/29/2016 08:30 | | 8/8/2016 |

These test results may be used for compliance purpose as required.

| Analyst | Tests |
|---------|-------|
| JP | 200.8 |



James Abston, Operations Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 358689

8/10/2016

Customer: G. S. Group
 Monica Starks
 17800 Woodward Ave #200
 Detroit, MI 48203

Source: Caesar Chavez, S-02-BF-02-F
Source City: Detroit
Source State: MI

Date/Time Received: 8/3/2016 14:00

Collected by: A. Hayden

The results herein conform to TNI and ISO/IEC 17025:2005 standards, where applicable, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

| Fed Id # | Contaminant | Method | Standard | Units | LRL | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|------------------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| Inorganic Analytes - Metals | | | | | | | | | | |
| 1030 | Lead | 200.8 | 0.015 | mg/L | 0.001 | ND | 1 | 7/29/2016 08:30 | | 8/8/2016 |

These test results may be used for compliance purpose as required.

| Analyst | Tests |
|---------|-------|
| JP | 200.8 |



James Abston, Operations Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

Laboratory ID: 0055

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 358690

8/10/2016

Customer: G. S. Group
Monica Starks
17800 Woodward Ave #200
Detroit, MI 48203

Source: Caesar Chavez, S-01-KC-03-P
Source City: Detroit
Source State: MI

Date/Time Received: 8/3/2016 14:00

Collected by: A. Hayden

The results herein conform to TNI and ISO/IEC 17025:2005 standards, where applicable, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

| Fed Id # | Contaminant | Method | Standard | Units | LRL | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|------------------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| Inorganic Analytes - Metals | | | | | | | | | | |
| 1030 | Lead | 200.8 | 0.015 | mg/L | 0.001 | 0.021* | 1 | 7/29/2016 08:30 | | 8/8/2016 |

These test results may be used for compliance purpose as required.

| Analyst | Tests |
|---------|-------|
| JP | 200.8 |



James Abston, Operations Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

ANALYTICAL REPORTS

SAMPLE CODE: 358691
8/10/2016

Customer: G. S. Group
 Monica Starks
 17800 Woodward Ave #200
 Detroit, MI 48203

Source: Caesar Chavez, S-01-KC-03-F
Source City: Detroit
Source State: MI

Date/Time Received: 8/3/2016 14:00
Collected by: A. Hayden

The results herein conform to TNI and ISO/IEC 17025:2005 standards, where applicable, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:
 Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

- "ND" This contaminant was not detected at or above our lower reporting limit (LRL)
- "NA" Not Analyzed
- "Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.
- "LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.
- "DF" This column indicates the contaminant dilution factor.

Report Notes:

| Fed Id # | Contaminant | Method | Standard | Units | LRL | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|------------------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| Inorganic Analytes - Metals | | | | | | | | | | |
| 1030 | Lead | 200.8 | 0.015 | mg/L | 0.001 | 0.010 | 1 | 7/29/2016 08:30 | | 8/8/2016 |

These test results may be used for compliance purpose as required.

| Analyst | Tests |
|---------|-------|
| JP | 200.8 |



James Abston, Operations Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd.

Quality Water Analysis

1-800-458-3330

General Compliance

Order Number: 2077783

358692

Order Date: 05/20/2016

Sample Number:



Product: Lead Only

Sample Paid: No Payment Method:

TSR: EF

Sold To:
G. S. Group
Monica Starks
17800 Woodward Ave
Detroit

MI 48203

Date Sampled: 7/29/16

Time Sampled: 8:30 Please Use Military Time, e.g. 3:00pm = 15:00

Check Time Zone: EST CST MST PST

Client Name: Caesar Chavez

Address: 4100 Martin

Phone Number: 313-909-8823

PWS ID# (if applicable): N/A

Sample ID or Source: S-02-GF-01-P

Source Type: Spring Well Municipal Surface
 Other:

City & State: Detroit, MI
(If Different than Above)

Sample Collected By: Aaron Hayden
(Signature)

Sample Collected By: Aaron Hayden
(Please Print)

Form Completed By: Michael Otters

Additional Comments:

The location sampled is a school. This is sample # 1, first draw.

For Laboratory Use ONLY

Lab Accounting Information:

Payment \$: _____

Check #: _____

Lab Comments/Special Instructions:

State Form:

Lab Sample Information:

Date Received: 8/3/16

Time Received: 14:00

Received By: DF

- Sample receipt criteria checked & acceptable.
- Deviations from acceptable sample receipt criteria noted on PSA form.

National Testing Laboratories, Ltd.

Quality Water Analysis

1-800-458-3330

General Compliance

Order Number: 2077783

Order Date: 05/20/2016

358693

Sample Number:



Product: Lead Only

Sample Paid: No Payment Method:

TSR: EF

Sold To:

G. S. Group

Monica Starks

17800 Woodward Ave

Detroit

MI 48203

Date Sampled: 7/29/16

Time Sampled: 8:30 Please Use Military Time, e.g. 3:00pm = 15:00

Check Time Zone: EST CST MST PST

Client Name: Caesar Chavez

Address: 4100 Martin

Phone Number: 313-909-8823

PWS ID# (if applicable): N/A

Sample ID or Source: S-02-GF-01-F

Source Type: Spring Well Municipal Surface Other:

City & State: Detroit, Mi. (If Different than Above)

Sample Collected By: Aaron Hayden (Signature)

Sample Collected By: Aaron Hayden (Please Print)

Form Completed By: Michael Effers

Additional Comments: The location sampled is a school, this is sample #1, flush sample.

| For Laboratory Use ONLY | |
|-------------------------------------|-----------------------------------------------------------------------|
| Lab Accounting Information: | |
| Payment \$: | _____ |
| Check #: | _____ |
| Lab Comments/Special Instructions: | |
| | |
| State Forms: | |
| | |
| Lab Sample Information: | |
| Date Received: | 8/3/16 |
| Time Received: | 14:00 |
| Received By: | BF |
| <input checked="" type="checkbox"/> | Sample receipt criteria checked & acceptable. |
| <input type="checkbox"/> | Deviations from acceptable sample receipt criteria noted on PSA form. |
| | |

INCOMPLETE INFORMATION MAY DELAY ANALYSIS AND/OR INVALIDATE RESULTS

National Testing Laboratories, Ltd.

Quality Water Analysis

1-800-458-3330

General Compliance

Order Number: 2077783
Order Date: 05/20/2016
Sample Number:
Product: Lead Only

358688



Sample Paid: No Payment Method:
TSR: EF

Sold To:
G. S. Group
Monica Starks
17800 Woodward Ave
Detroit MI 48203

Date Sampled: 7/29/16

Time Sampled: 8:30 Please Use Military Time, e.g. 3:00pm = 15:00

Check Time Zone: EST CST MST PST

Client Name: Caesar Chavez

Address: 4100 Martin

Phone Number: 313-909-8823

PWS ID# (if applicable): N/A

Sample ID or Source: S-02-BF-02-7

Source Type: Spring Well Municipal Surface
 Other:

City & State: Detroit, Mi.
(If Different than Above)

Sample Collected By: Aaron Hayden
(Signature)

Sample Collected By: Aaron Hayden
(Please Print)

Form Completed By: Michael Atkins

Additional Comments: The location sampled is a school. This is sample # 2, first draw.

| For Laboratory Use ONLY | |
|-------------------------------------|-----------------------------------------------------------------------|
| Lab Accounting Information: | |
| Payment \$: | _____ |
| Check #: | _____ |
| Lab Comments/Special Instructions: | |
| | |
| State Forms: | |
| | |
| Lab Sample Information: | |
| Date Received: | 8/3/16 |
| Time Received: | 14:00 |
| Received By: | SA |
| <input checked="" type="checkbox"/> | Sample receipt criteria checked & acceptable. |
| <input type="checkbox"/> | Deviations from acceptable sample receipt criteria noted on PSA form. |

National Testing Laboratories, Ltd.

Quality Water Analysis

1-800-458-3330

General Compliance

Order Number: 2077783

Order Date: 05/20/2016

358689

Sample Number:



Product: Lead Only

Sample Paid: No

Payment Method:

TSR: EF

Sold To:

G. S. Group

Monica Starks

17800 Woodward Ave

Detroit

MI 48203

| For Laboratory Use ONLY | |
|------------------------------------------------------------------------------------------------|--------|
| Lab Accounting Information: | |
| Payment \$: | _____ |
| Check #: | _____ |
| Lab Comments/Special Instructions: | |
| | |
| State Forms: | |
| | |
| Lab Sample Information: | |
| Date Received: | 8/3/16 |
| Time Received: | 14:00 |
| Received By: | BF |
| <input checked="" type="checkbox"/> Sample receipt criteria checked & acceptable. | |
| <input type="checkbox"/> Deviations from acceptable sample receipt criteria noted on PSA form. | |

Date Sampled: 7/29/16

Time Sampled: 8:30 Please Use Military Time, e.g. 3:00pm = 15:00

Check Time Zone: EST CST MST PST

Client Name: Caesar Chavez
4100 Martin

Number: 313-909-8823

PWS ID# (if applicable): N/A

Sample ID or Source: S-02-BF-02-F

Source Type: Spring Well Municipal Surface

City & State: Detroit, Mi.

Sample Collected By: Aaron Hayden (Signature)

Sample Collected By: Aaron Hayden (Please Print)

Form Completed By: Michael Peters

Additional Comments: The location sampled is a school. This is sample # 2, Flush Sample.

National Testing Laboratories, Ltd.

Quality Water Analysis

1-800-458-3330

General Compliance

Order Number: 2077783
Order Date: 05/20/2016
Sample Number:
Product: Lead Only

358691



Sample Paid: No Payment Method:
TSR: EF

Sold To:
G. S. Group
Monica Starks
17800 Woodward Ave
Detroit

MI 48203

Date Sampled: 7/29/16

Time Sampled: 8:30 Please Use Military Time, e.g. 3:00pm = 15:00

Check Time Zone: EST CST MST PST

Client Name: Caesar Chavez
4100 Martin

Phone Number: 313-909-8823

PWS ID# (if applicable): N/A

Sample ID or Source: S-01-Kc-03-F

Source Type: Spring Well Municipal Surface
 Other:

City & State: Detroit, MI
(If Different than Above)

Sample Collected By: Aaron Hayden
(Signature)

Sample Collected By: Aaron Hayden
(Please Print)

Form Completed By: Michael Effers

Additional Comments: The location sampled is a school. This is sample #3, flush sample.

| For Laboratory Use ONLY | |
|------------------------------------------------------------------------------------------------|--------|
| Lab Accounting Information: | |
| Payment \$: | _____ |
| Check #: | _____ |
| Lab Comments/Special Instructions: | |
| | |
| State Forms: | |
| | |
| Lab Sample Information: | |
| Date Received: | 8/3/16 |
| Time Received: | 14:00 |
| Received By: | DF |
| <input checked="" type="checkbox"/> Sample receipt criteria checked & acceptable. | |
| <input type="checkbox"/> Deviations from acceptable sample receipt criteria noted on PSA form. | |