

9/7/2016

Detroit Health Department
3245 E. Jefferson Ave, Suite 100
Detroit, MI 48207

Subject: **Cornerstone Schools Association**
6861 Nevada Avenue, Detroit, MI, 48234

Dear Detroit Health Department:

A KITCHEN SINK OUTLET WAS TESTED AND MEASURED AT AN ELEVATED LEAD LEVEL. MITIGATING ACTION WAS TAKEN.

AT THE ABOVE NAMED OUTLET, EXISTING METAL PIPING WAS REPLACED WITH PVC PIPING; NEW FIXTURES WERE INSTALLED TO REPLACE THE EXISTING FIXTURES.

UPON THIRD PARTY RETEST, NO LEAD WAS DETECTED.

NO OTHER OUTLETS TESTED ON SITE YIELDED ELEVATED LEAD LEVEL MEASUREMENTS.

Sincerely,

A handwritten signature in black ink, appearing to read 'Joshua Britton', with a long horizontal flourish extending to the right.

Joshua Britton