

May 9, 2016

Matt Vallevand  
Detroit Health Department  
3245 E. Jefferson Ave, Ste 100  
Detroit, MI 48207

Dear Mr. Vallevand:

On Thursday, April 28th, an environmental consultant from Nova Environmental, Inc. conducted the water sample collection within all U Prep Schools buildings. Attached please find the results from the Lead/Copper Water Sampling covering the following campuses:

**University Prep Academy High School**  
600 Antoinette  
Detroit, MI 48202

**University Prep Science and Math Elementary**  
2251 Antietam  
Detroit, MI 48207

**Mark Murray Campus**  
435 Amsterdam  
Detroit, MI 48202

**University Prep Science and Math Middle School**  
5100 John R  
Detroit, MI 48202

**Ellen Thompson Campus**  
957 Holden  
Detroit, MI 48202

**University Prep Science and Math High School**  
2664 Franklin  
Detroit, MI 48207

**UPA Middle School**  
5301 St. Antoine  
Detroit, MI 48202

If you require additional information, feel free to contact me at 313.920.3350.

Sincerely,



D. Nicole Cummings  
Executive Director of Operations  
University Prep Schools c/o Detroit 90/90

**BOARD OF DIRECTORS**

**DETROIT 90/90**

Vincent DeAngelis  
Pastor Marcus Ways  
Francis Resendes

**PUBLIC SCHOOL ACADEMIES OF DETROIT (PSAD)**

Edward Parks  
James Nicholson  
Keith Cooley  
Kyle Chandler

Denise Lewis  
Zina Kramer  
Jerrold Jung  
Karen Obsniuk

Joseph Aristeo  
Michael Porter  
John Cleary

University Prep Academy High School

Building A - Red Building

Sample ID - Primary	Lead	Copper	Sample ID - Flush	Lead	Copper	Location
187420 - P	ND	0.340 mg/L	187443 - F	N/A	N/A	Concession Stand Faucet
187464 - P	ND	0.058 mg/L	187446 - F	N/A	N/A	Lower Drinking Fountain, Gym
187417 - P	ND	0.200 mg/L	187427 - F	N/A	N/A	Faucet, Management Office

Building B - Purple Building

Sample ID - Primary	Lead	Copper	Sample ID - Flush	Lead	Copper	Location
187424 - P	ND	0.300 mg/L	187446 - F	N/A	N/A	Prep Faucet, Kitchen
187465 - P	ND	0.230 mg/L	187436 - F	N/A	N/A	Lower Drinking Fountain, Hall near Restrooms
187425 - P	ND	0.250 mg/L	187431 - F	N/A	N/A	Faucet, Staff Work Room

Building C - Blue Building

Sample ID - Primary	Lead	Copper	Sample ID - Flush	Lead	Copper	Location
187426 - P	ND	0.280 mg/L	187449 - F	N/A	N/A	Prep Faucet, Kitchen
187418 - P	ND	0.064 mg/L	187429 - F	N/A	N/A	Lower Drinking Fountain, Hall near Restrooms
187434 - P	ND	0.230 mg/L	187435 - F	N/A	N/A	Faucet, Staff Work Room

Building D - Yellow Building

Sample ID - Primary	Lead	Copper	Sample ID - Flush	Lead	Copper	Location
187419 - P	ND	0.200 mg/L	187442 - F	N/A	N/A	Prep Faucet, Kitchen
187440 - P	ND	0.210 mg/L	187439 - F	N/A	N/A	Lower Drinking Fountain, near Restrooms
187447 - P	ND	0.430 mg/L	187444 - F	N/A	N/A	Faucet, Staff Work Room

Building E - Green Building

Sample ID - Primary	Lead	Copper	Sample ID - Flush	Lead	Copper	Location
187422 - P	ND	0.200 mg/L	187438 - F	N/A	N/A	Prep Faucet, Kitchen
187423 - P	ND	0.180 mg/L	187430 - F	N/A	N/A	Upper Drinking Fountain, Hall near Restrooms
187421 - P	0.001 mg/L	0.400 mg/L	187428 - F	N/A	N/A	Faucet, Staff Work Room

Laboratory ID: 0055

**National Testing Laboratories, Ltd**  
556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 354046**

**5/4/2016**

**Customer:** Nova Environmental Inc.  
Kary Amin  
5300 Plymouth Road  
Ann Arbor, MI 48105

**Source:** UPS-High School-Red Building, 187420-P  
**Source City:** Detroit  
**Source State:** MI

**Date/Time Received:** 4/28/2016 15:30

**Collected by:** K. Amin

The results herein conform to TNI and ISO/IEC 17025:2005 standards, where applicable, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

**Report Notes:**

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1022	Copper	200.8	1.0	mg/L	0.002	0.340	1	4/28/2016 05:32		5/2/2016
1030	Lead	200.8	0.015	mg/L	0.001	ND	1	4/28/2016 05:32		5/2/2016

These test results may be used for compliance purpose as required.

Analyst	Tests
EC	200.8



James Abston, Operations Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

Laboratory ID: 0055

**National Testing Laboratories, Ltd**  
556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 354048**

**5/4/2016**

**Customer:** Nova Environmental Inc.  
Kary Amin  
5300 Plymouth Road  
Ann Arbor, MI 48105

**Source:** UPS-High School-Red Building, 187464-P  
**Source City:** Detroit  
**Source State:** MI

**Date/Time Received:** 4/28/2016 15:30

**Collected by:** K. Amin

The results herein conform to TNI and ISO/IEC 17025:2005 standards, where applicable, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

**Report Notes:**

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1022	Copper	200.8	1.0	mg/L	0.002	0.058	1	4/28/2016 05:34		5/2/2016
1030	Lead	200.8	0.015	mg/L	0.001	ND	1	4/28/2016 05:34		5/2/2016

These test results may be used for compliance purpose as required.

Analyst	Tests
EC	200.8



James Abston, Operations Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd*

Laboratory ID: 0055

**National Testing Laboratories, Ltd**  
556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 354050**

**5/4/2016**

**Customer:** Nova Environmental Inc.  
Kary Amin  
5300 Plymouth Road  
Ann Arbor, MI 48105

**Source:** UPS-High School-Red Building, 187417-P  
**Source City:** Detroit  
**Source State:** MI

**Date/Time Received:** 4/28/2016 15:30

**Collected by:** K. Amin

The results herein conform to TNI and ISO/IEC 17025:2005 standards, where applicable, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.


"DF" This column indicates the contaminant dilution factor.

**Report Notes:**

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1022	Copper	200.8	1.0	mg/L	0.002	0.200	†	4/28/2016 05:38		5/2/2016
1030	Lead	200.8	0.015	mg/L	0.001	ND	†	4/28/2016 05:38		5/2/2016

These test results may be used for compliance purpose as required.

Analyst	Tests
EC	200.8



James Abston, Operations Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*