

May 9, 2016

Matt Vallevand
Detroit Health Department
3245 E. Jefferson Ave, Ste 100
Detroit, MI 48207

Dear Mr. Vallevand:

On Thursday, April 28th, an environmental consultant from Nova Environmental, Inc. conducted the water sample collection within all U Prep Schools buildings. Attached please find the results from the Lead/Copper Water Sampling covering the following campuses:

University Prep Academy High School
600 Antoinette
Detroit, MI 48202

University Prep Science and Math Elementary
2251 Antietam
Detroit, MI 48207

Mark Murray Campus
435 Amsterdam
Detroit, MI 48202

University Prep Science and Math Middle School
5100 John R
Detroit, MI 48202

Ellen Thompson Campus
957 Holden
Detroit, MI 48202

University Prep Science and Math High School
2664 Franklin
Detroit, MI 48207

UPA Middle School
5301 St. Antoine
Detroit, MI 48202

If you require additional information, feel free to contact me at 313.920.3350.

Sincerely,



D. Nicole Cummings
Executive Director of Operations
University Prep Schools c/o Detroit 90/90

BOARD OF DIRECTORS

DETROIT 90/90

Vincent DeAngelis
Pastor Marcus Ways
Francis Resendes

PUBLIC SCHOOL ACADEMIES OF DETROIT (PSAD)

Edward Parks
James Nicholson
Keith Cooley
Kyle Chandler

Denise Lewis
Zina Kramer
Jerrold Jung
Karen Obsniuk

Joseph Aristeo
Michael Porter
John Cleary

University Prep Academy High School

Building A - Red Building

Sample ID - Primary	Lead	Copper	Sample ID - Flush	Lead	Copper	Location
187420 - P	ND	0.340 mg/L	187443 - F	N/A	N/A	Concession Stand Faucet
187484 - P	ND	0.058 mg/L	187446 - F	N/A	N/A	Lower Drinking Fountain, Gym
187417 - P	ND	0.200 mg/L	187427 - F	N/A	N/A	Faucet, Management Office

Building B - Purple Building

Sample ID - Primary	Lead	Copper	Sample ID - Flush	Lead	Copper	Location
187424 - P	ND	0.300 mg/L	187446 - F	N/A	N/A	Prep Faucet, Kitchen
187465 - P	ND	0.230 mg/L	187436 - F	N/A	N/A	Lower Drinking Fountain, Hall near Restrooms
187425 - P	ND	0.250 mg/L	187431 - F	N/A	N/A	Faucet, Staff Work Room

Building C - Blue Building

Sample ID - Primary	Lead	Copper	Sample ID - Flush	Lead	Copper	Location
187426 - P	ND	0.280 mg/L	187449 - F	N/A	N/A	Prep Faucet, Kitchen
187418 - P	ND	0.064 mg/L	187429 - F	N/A	N/A	Lower Drinking Fountain, Hall near Restrooms
187434 - P	ND	0.230 mg/L	187435 - F	N/A	N/A	Faucet, Staff Work Room

Building D - Yellow Building

Sample ID - Primary	Lead	Copper	Sample ID - Flush	Lead	Copper	Location
187419 - P	ND	0.200 mg/L	187442 - F	N/A	N/A	Prep Faucet, Kitchen
187440 - P	ND	0.210 mg/L	187439 - F	N/A	N/A	Lower Drinking Fountain, near Restrooms
187447 - P	ND	0.430 mg/L	187444 - F	N/A	N/A	Faucet, Staff Work Room

Building E - Green Building

Sample ID - Primary	Lead	Copper	Sample ID - Flush	Lead	Copper	Location
187422 - P	ND	0.200 mg/L	187438 - F	N/A	N/A	Prep Faucet, Kitchen
187423 - P	ND	0.180 mg/L	187430 - F	N/A	N/A	Upper Drinking Fountain, Hall near Restrooms
187421 - P	0.001 mg/L	0.400 mg/L	187428 - F	N/A	N/A	Faucet, Staff Work Room

Laboratory ID: 0055

National Testing Laboratories, Ltd
556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 354064

5/4/2016

Customer: Nova Environmental Inc.
Kary Amin
5300 Plymouth Road
Ann Arbor, MI 48105

Source: UPS-High School-Yellow Building, 187419-P
Source City: Detroit
Source State: MI

Date/Time Received: 4/28/2016 15:30

Collected by: K. Amin

The results herein conform to TNI and ISO/IEC 17025:2005 standards, where applicable, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.


"DF" This column indicates the contaminant dilution factor.

Report Notes:

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1022	Copper	200.8	1.0	mg/L	0.002	0.200	1	4/28/2016 06:12		5/2/2016
1030	Lead	200.8	0.015	mg/L	0.001	ND	1	4/28/2016 06:12		5/2/2016

These test results may be used for compliance purpose as required.

Analyst	Tests
EC	200.8



James Abston, Operations Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

Laboratory ID: 0055

National Testing Laboratories, Ltd
556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 354066

5/4/2016

Customer: Nova Environmental Inc.
Kary Amin
5300 Plymouth Road
Ann Arbor, MI 48105

Source: UPS-High School-Yellow Building, 187440-P
Source City: Detroit
Source State: MI

Date/Time Received: 4/28/2016 15:30

Collected by: K. Amin

The results herein conform to TNI and ISO/IEC 17025:2005 standards, where applicable, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1022	Copper	200.8	1.0	mg/L	0.002	0.210	1	4/28/2016 08:15		5/2/2016
1030	Lead	200.8	0.015	mg/L	0.001	ND	1	4/28/2016 08:15		5/2/2016

These test results may be used for compliance purpose as required.

Analyst	Tests
EC	200.8



James Abston, Operations Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd

Laboratory ID: 0055

National Testing Laboratories, Ltd
556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 354068

5/4/2016

Customer: Nova Environmental Inc.
Kary Amin
5300 Plymouth Road
Ann Arbor, MI 48105

Source: UPS-High School-Yellow Building, 187447-P
Source City: Detroit
Source State: MI

Date/Time Received: 4/28/2016 15:30

Collected by: K. Amin

The results herein conform to TNI and ISO/IEC 17025:2005 standards, where applicable, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1022	Copper	200.8	1.0	mg/L	0.002	0.430	1	4/28/2016 06:20		5/2/2016
1030	Lead	200.8	0.015	mg/L	0.001	ND	1	4/28/2016 06:20		5/2/2016

These test results may be used for compliance purpose as required.

Analyst	Tests
EC	200.8



James Abston, Operations Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.