

**DETROIT PUBLIC SCHOOLS COMMUNITY DISTRICT (DPSCD)
DRINKING WATER MITIGATION PLAN**

School Name: Turning Point		Address: 12300 Linnhurst	
Date:	July 25, 2016 Revised August 9, 2016	Enrollment:	103
Mitigation Action Plan 2:	(1) Implement Flush Plan for remaining fixtures that do not exceed the MCL of initial and/or flush sample according to MDEQ Guidance and the EPA's 3Ts for Reducing Lead in Drinking Water in Schools. (2) Continue to isolate and/or remove the fixture: DWF-P-TP-Hall @ Office, DWF-P-TP-Hall from 102		
Hazard (s) Addressed:	Elevated level of lead and/or copper detected in school drinking water		
Responsible Department:	DPS, Department of Environmental Health and Safety		
Implementation Schedule:	Ongoing, beginning July 2016; Annual testing based on results		

Submitted by: _____ *Felicia Venable* _____

Date: 8/30/16

Felicia Venable, Acting Executive Director- Operations
Division of Finance and Operations

Reviewed and Approved by: _____ *Abdul El-Sayed* _____

Date: 8-30-2016

Abdul El-Sayed, MD, DPhil
Executive Director & Health Officer
City of Detroit